



Decision Notice Approval (amended)

Planning Act Form 5 (version 1.2 effective 7 February 2020) made under Section 282 of the Planning Act 2016 for a decision notice (approval) under s83 Planning Act 2016

Application number:	D/66-2021	Contact:	Amanda O'Mara
Notice Date:	18 March 2022	Contact Number:	07 4936 8099

APPLICANT DETAILS

Name:	Kele Property Group (Qld) Pty Ltd		
Postal address:	C/- Gideon Town Planning		
Phone no:	Mobile no:	Email:	

I acknowledge receipt of the above change application on 3 February 2022 and confirm the following:

DEVELOPMENT APPROVAL

Development Permit for a Material Change of Use for a Multiple Dwelling (18 Dwellings)

PROPERTY DESCRIPTION

Street address:	99 Pennycuik Street and 101 Pennycuik Street, West Rockhampton
Real property description:	Lot 4 and 3 on RP892683, Parish of Rockhampton

OWNER DETAILS

Name:	Kele Property Group (Qld) Pty Ltd
Postal address:	
Dear Kele Property Group (Qld) Pty Ltd	
I advise that, on 8 March 2022 the above change application was:	
<input checked="" type="checkbox"/> approved in full with conditions* (refer to the conditions contained in Attachment 1)	
*Note: The conditions show which conditions have been imposed by the assessment manager and which conditions have been imposed by a referral agency.	

CHANGES TO CONDITIONS

The conditions which have been changed or cancelled are as follows:

1)	Item 7	Changed	8 March 2022
2)	Condition 1.9	Changed	8 March 2022
3)	Condition 2.1	Changed	8 March 2022
4)	Condition 4.8	Changed	8 March 2022

1. DETAILS OF THE APPROVAL

The following approvals are given:

	Development Permit	Preliminary Approval
Development assessable under the planning scheme, superseded planning scheme, a temporary local planning instrument, a master plan or a preliminary approval which includes a variation approval - Material change of use	<input checked="" type="checkbox"/>	<input type="checkbox"/>

2. CONDITIONS

This approval is subject to the conditions in Attachment 1.

3. FURTHER DEVELOPMENT PERMITS REQUIRED

Please be advised that the following development permits are required to be obtained before the development can be carried out:

Type of development permit required	Subject of the required development permit
Operational Works	<i>Road Works</i> <i>Access and Parking Works</i> <i>Sewerage Works</i> <i>Stormwater Works</i> <i>Site Works</i> <i>Landscaping Works</i> <i>Roof and Allotment Drainage Works</i>
Building Works	<i>Demolition Works</i> <i>Building Works</i>
Plumbing and Drainage Works	

4. SUSMISSIONS NIL

5. REFERRAL AGENCIES NIL

6. THE APPROVED PLANS

The approved development must be completed and maintained generally in accordance with the approved drawings and documents:

<u>Plan/Document Name</u>	<u>Prepared by</u>	<u>Date</u>	<u>Reference No.</u>	<u>Version/Issue</u>
Proposed Site Plan	design + architecture	11 February 2022	SK-001	52
Street Elevation	design + architecture	28 January 2022	SK-002	51
Unit A	design + architecture	28 January 2022	SK-003	51
Unit B	design + architecture	28 January 2022	SK-004	51
Unit C	design + architecture	28 January 2022	SK-005	51
Unit D	design + architecture	28 January 2022	SK-006	51
Locality Plan	McMurtrie Consulting Engineers	2 June 2021	0772021-P-0001	B
Preliminary Site Layout and Vehicle Swept Paths	McMurtrie Consulting Engineers	27 April 2021	0772021-P-0002	A

Preliminary Earthwork Layout Plan	McMurtrie Consulting Engineers	27 April 2021	0772021-P-0003	A
Preliminary Services Layout Plan	McMurtrie Consulting Engineers	2 June 2021	0772021-P-0004	B
Stormwater Management Plan	McMurtrie Consulting Engineers	27 May 2021	036-20-21	B
Technical Memorandum (Flood Statement)	McMurtrie Consulting Engineers	31 May 2021	077-20-21	-

7. CURRENCY PERIOD FOR THE APPROVAL (s.85 of the Planning Act)

The standard relevant periods stated in section 85 of *Planning Act 20016* apply to each aspect of development in this approval, if not stated in the conditions of approval attached.

8. STATEMENT OF REASONS

Description of the development	The proposed development is for a Material Change of Use for a Multiple Dwelling (18 Dwellings)		
Reasons for Decision	<p>a) The proposal will expand on the range of housing opportunities available to the local community within an established residential zone;</p> <p>b) The built form and density of the proposal, being single storey with design elements that reflect the character of the surrounding neighbourhood, ensures the development does not impact the residential amenity;</p> <p>c) The development is located in an established residential area, within close proximity to a minor urban collector road, that is well serviced with public transport and urban infrastructure and services;</p> <p>d) Assessment of the development against the relevant zone purpose, planning scheme codes and planning scheme policies demonstrates that the proposed development will not cause significant adverse impacts on the surrounding natural environment, built environment and infrastructure, community facilities, or local character and amenity; and</p> <p>e) On balance, the application should be approved because the circumstances favour Council exercising its discretion to approve the application even though the development does not comply with an aspect of the assessment benchmarks.</p>		
Assessment Benchmarks	<p>The proposed development was assessed against the following assessment benchmarks:</p> <ul style="list-style-type: none"> • Strategic Framework; • Low Density Residential Zone Code; • Access, Parking And Transport Code; • Filling and Excavation Code; • Landscape Code; • Stormwater Management Code; and • Water and Sewer Code. 		
Compliance with assessment benchmarks	The development was assessed against all of the assessment benchmarks listed above and complies with all of these with the exception listed below.		
	Assessment Benchmark	Reasons for the approval despite non-compliance with benchmark	
	Low Density Residential Zone Code	<p>PO18</p> <p>The proposal does not comply with AO18.1 which states public transport or a centre must be within 200 metres of the site. However, the site is in close proximity to the Botanical Gardens, a golf course and within an established residential area where public transport is available. In addition, the</p>	

		proposal does not comply with AO18.2 which requires the site to have direct access to a minor urban collector road or higher order road. However, the proposal is located on an urban access place and is within 200 metres to a minor urban collector. Therefore, the proposal provides additional housing in an area which is highly accessible and located to minimise impacts on the local street network.
Matters prescribed by regulation	<ul style="list-style-type: none"> • The <i>Rockhampton Region Planning Scheme 2015</i> (version 2.2); and • The common material, being the material submitted with the application. 	

9. RIGHTS OF APPEAL

The rights of an applicant to appeal to a tribunal or the Planning and Environment Court against a decision about a development application are set out in chapter 6, part 1 of the *Planning Act 2016*. For particular applications, there may also be a right to make an application for a declaration by a tribunal (see chapter 6, part 2 of the *Planning Act 2016*).

Appeal by an applicant

An applicant for a development application may appeal to the Planning and Environment Court against the following:

- the refusal of all or part of the development application
- a provision of the development approval
- the decision to give a preliminary approval when a development permit was applied for
- a deemed refusal of the development application.

An applicant may also have a right to appeal to the Development tribunal. For more information, see schedule 1 of the *Planning Act 2016*.

The timeframes for starting an appeal in the Planning and Environment Court are set out in section 229 of the *Planning Act 2016*.

Attachment 2 is an extract from the *Planning Act 2016* that sets down the applicant's appeal rights and the appeal rights of a submitter.

10. WHEN THE DEVELOPMENT APPROVAL TAKES EFFECT

This development approval takes effect:

- From the time the decision notice is given – if there is no submitter and the applicant does not appeal the decision to the court.

Or

- When the submitter's appeal period ends – if there is a submitter and the applicant does not appeal the decision to the court.

Or

- Subject to the decision of the court, when the appeal is finally decided – if an appeal is made to the court.

11. ORIGINAL DECISION ASSESSMENT MANAGER

Name: Tarnya Fitzgibbon COORDINATOR DEVELOPMENT ASSESSMENT	Date: 31 August 2021
---	----------------------

12. ASSESSMENT MANAGER

Name: Tarnya Fitzgibbon COORDINATOR DEVELOPMENT ASSESSMENT	Signature:	Date: 18 March 2022
---	------------	---------------------

Attachment 1 – Conditions of the approval

Part 1 – Conditions imposed by the assessment manager [Note: where a condition is imposed about infrastructure under Chapter 4 of the Planning Act 2016, the relevant provision of the Act under which this condition was imposed must be specified.]

Attachment 2—Extract on appeal rights

ADMINISTRATION

- 1.1 The Developer and their employee, agent, contractor or invitee is responsible for ensuring compliance with the conditions of this development approval.
- 1.2 Where these Conditions refer to “Council” in relation to requiring Council to approve or to be satisfied as to any matter, or conferring on the Council a function, power or discretion, that role may be fulfilled in whole or in part by a delegate appointed for that purpose by the Council.
- 1.3 All conditions, works, or requirements of this development approval must be undertaken, completed, and be accompanied by a Compliance Certificate for any operational works required by this development approval:
 - 1.3.1 to Council’s satisfaction;
 - 1.3.2 at no cost to Council; and
 - 1.3.3 prior to the commencement of the useunless otherwise stated.
- 1.4 Infrastructure requirements of this development approval must be contributed to the relevant authorities, where applicable, at no cost to Council, prior to the commencement of the use, unless otherwise stated.
- 1.5 The following further Development Permits must be obtained prior to the commencement of any works associated with their purposes:
 - 1.5.1 Operational Works:
 - (i) Road Works;
 - (ii) Access and Parking Works;
 - (iii) Sewerage Works;
 - (iv) Stormwater Works;
 - (v) Roof and Allotment Drainage;
 - (vi) Site Works; and
 - (vii) Landscaping Works.
 - 1.5.2 Plumbing and Drainage Works
 - 1.5.3 Building Works:
 - (i) Demolition Works; and
 - (ii) Building Works.
- 1.6 All Development Permits for Operational Works and Plumbing and Drainage Works must be obtained prior to the issue of a Development Permit for Building Works.
- 1.7 All works must be designed, constructed and maintained in accordance with the relevant Council policies, guidelines and standards, unless otherwise stated.
- 1.8 All engineering drawings/specifications, design and construction works must be in accordance with the requirements of the relevant *Australian Standards* and must be approved, supervised and certified by a Registered Professional Engineer of Queensland.

1.9 The Reconfiguring a Lot Development Approval (D/147-2021) for a boundary realignment between Lot 3 RP892683 and Lot 4 RP892683 must be completed and registered prior to the commencement of use.

2.0 APPROVED PLANS AND DOCUMENTS

2.1 The approved development must be completed and maintained generally in accordance with the approved plans and documents, except where amended by any condition of this development approval:

<u>Plan/Document Name</u>	<u>Prepared by</u>	<u>Date</u>	<u>Reference No.</u>	<u>Version/ Issue</u>
Proposed Site Plan	design + architecture	11 February 2022	SK-001	52
Street Elevation	design + architecture	28 January 2022	SK-002	51
Unit A	design + architecture	28 January 2022	SK-003	51
Unit B	design + architecture	28 January 2022	SK-004	51
Unit C	design + architecture	28 January 2022	SK-005	51
Unit D	design + architecture	28 January 2022	SK-006	51
Locality Plan	McMurtrie Consulting Engineers	2 June 2021	0772021-P-0001	B
Preliminary Site Layout and Vehicle Swept Paths	McMurtrie Consulting Engineers	27 April 2021	0772021-P-0002	A
Preliminary Earthwork Layout Plan	McMurtrie Consulting Engineers	27 April 2021	0772021-P-0003	A
Preliminary Services Layout Plan	McMurtrie Consulting Engineers	2 June 2021	0772021-P-0004	B
Stormwater Management Plan	McMurtrie Consulting Engineers	27 May 2021	036-20-21	B
Technical Memorandum (Flood Statement)	McMurtrie Consulting Engineers	31 May 2021	077-20-21	-

2.2 Where there is any conflict between the conditions of this development approval and the details shown on the approved plans and documents, the conditions of this development approval must prevail.

2.3 Where conditions require the above plans or documents to be amended, the revised document(s) must be submitted for approval by Council prior to the submission of an application for a Development Permit for Operational Works.

3.0 ROAD WORKS

3.1 A Development Permit for Operational Works (road works) must be obtained prior to the commencement of any road works on for the development site.

3.2 All road works must be designed and constructed in accordance with the approved plans (refer to condition 2.1), *Capricorn Municipal Development Guidelines*, relevant

Australian Standards and the provisions of a Development Permit for Operational Works (road works).

- 3.3 A concrete pathway, with a minimum width of 1.2 metres, must be constructed on the eastern side of Pennycuick Street for the full frontage of the development site.

4.0 ACCESS AND PARKING WORKS

- 4.1 A Development Permit for Operational Works (access and parking works) must be obtained prior to the commencement of any access and parking works on the development site.

- 4.2 All access and parking works must be designed and constructed in accordance with the approved plans (refer to condition 2.1), *Capricorn Municipal Development Guidelines*, *Australian Standard AS2890 "Parking facilities"* and the provisions of a Development Permit for Operational Works (access and parking works).

- 4.3 All car parking and access areas must be paved or sealed to Council's satisfaction. Design and construction must be in accordance with the provisions of a Development Permit for Operational Works (access and parking works).

- 4.4 The existing access from Pennycuick Street to the development must be upgraded to comply with the requirements of the *Capricorn Municipal Development Guidelines*.

- 4.5 Any redundant vehicular crossovers must be replaced by Council standard kerb and channel.

- 4.6 All vehicles must ingress and egress the development in a forward gear.

- 4.7 Adequate sight distances must be provided for all ingress and egress movements at the access driveways in accordance with *Australian Standard AS2890.2 "Parking facilities - Off street commercial vehicle facilities"*.

- 4.8 A minimum of forty (40) parking spaces must be provided on-site.

- 4.9 Parking spaces must be line-marked in accordance with the approved Site Plan (refer to condition 2.1) and in accordance with the *Australian Standard AS2890 "Parking facilities"* and the provisions of a Development Permit for Operational Works (access and parking works).

- 4.10 Any application for a Development Permit for Operational Works (access and parking works) must be accompanied by detailed and scaled plans, which demonstrate the turning movements/swept paths of the largest vehicle to access the development site including refuse collection vehicles.

- 4.11 All vehicle operations associated with the development must be directed by suitable directional, informative, regulatory or warning signs in accordance with *Australian Standard AS1742.1 "Manual of uniform traffic control devices"* and *Australian Standard AS2890.1 "Parking facilities – Off-street car parking"*.

- 4.12 Road signage and pavement markings must be installed in accordance with *Australian Standard AS1742.1 "Manual of uniform traffic control devices"*.

- 4.13 All vehicle operation areas must be illuminated in accordance with the requirements of *Australian Standard AS1158 "Lighting for roads and public spaces"*.

5.0 SEWERAGE WORKS

- 5.1 A Development Permit for Operational Works (sewerage works) must be obtained prior to the commencement of any sewerage works on the development site.

- 5.2 All sewerage works must be designed and constructed in accordance with the approved plans (refer to condition 2.1), *Capricorn Municipal Development Guidelines*, *Water Supply (Safety and Reliability) Act 2008*, *Plumbing and Drainage Act 2018* and the provisions of a Development Permit for Operational Works (sewerage works).

- 5.3 The development must be connected to Council's reticulated sewerage network.

- 5.4 A new sewerage access chamber must be installed over existing 150 millimetre diameter sewerage main within the site. A new sewerage connection point must be provided from this access chamber to service the development. This non-trunk infrastructure is conditioned under section 145 of the *Planning Act 2016*.
- 5.5 The existing sewerage connection point(s) must be disconnected.
- 5.6 The finished sewerage access chamber surface must be at a sufficient level to avoid ponding of stormwater above the top of the chamber. A heavy duty trafficable lid must be provided in the trafficable area.
- 5.7 The proposed sewerage infrastructure internal to the site except existing 150 millimetre diameter sewerage main must be privately owned sewerage infrastructure and must be maintained by the owner at no cost to Council.
- 5.8 Large trees must not be planted within one (1) metre of the centreline of any sewerage infrastructure owned by Council; small shrubs and groundcover are acceptable.
- 6.0 WATER WORKS
- 6.1 All water works must be designed and constructed in accordance with the approved plans (refer to condition 2.1), *Capricorn Municipal Development Guidelines, Water Supply (Safety and Reliability) Act 2008* and *Plumbing and Drainage Act 2018*.
- 6.2 The development must be connected to Council's reticulated water network.
- 6.3 The existing water connection point(s) at Pennycuik Street road reserve must be disconnected. A new water connection point must be provided to the development. An hydraulic engineer or other suitably qualified person must determine the size of connection required.
- 6.4 Adequate domestic and firefighting protection must be provided to the development, in accordance with *Australian Standard AS2419 "Fire Hydrant Installations"* and must be certified by an hydraulic engineer or other suitably qualified person.
- 6.5 The development must be provided with a master meter at the development site boundary and sub-meters for each sole occupancy building in accordance with the *Queensland Plumbing and Drainage Code* and Council's Sub-metering Policy.
- 6.6 If required, the existing Fire Hydrant (FH) at proposed vehicle crossover must be re-located under a private works quote.
- 6.7 The proposed water supply infrastructure internal to the site must be privately owned water supply infrastructure and must be maintained by the owner at no cost to Council.
- 6.8 Water meter boxes located within trafficable areas must be raised or lowered to suit the finished surface levels and must be provided with heavy duty trafficable lids.
- 7.0 PLUMBING AND DRAINAGE WORKS
- 7.1 A Development Permit for Plumbing and Drainage Works must be obtained for the removal and/or demolition of any existing structures and proposed new structures on the development site.
- 7.2 All internal plumbing and drainage works must be designed and constructed in accordance with the approved plans (refer to condition 2.1), *Capricorn Municipal Development Guidelines, Water Supply (Safety and Reliability) Act 2008, Plumbing and Drainage Act 2018*, Council's Plumbing and Drainage Policies and the provisions of a Development Permit for Plumbing and Drainage Works.
- 7.3 All internal plumbing and sanitary drainage works must be completely independent for each dwelling unit.
- 7.4 Disconnection of internal plumbing and sanitary drainage works associated with the existing buildings must be in accordance with regulated work under the *Plumbing and Drainage Act 2018* and Council's Plumbing and Drainage Policies.

8.0 STORMWATER WORKS

- 8.1 A Development Permit for Operational Works (stormwater works) must be obtained prior to the commencement of any stormwater works required by this development approval.
- 8.2 All stormwater drainage works must be designed and constructed in accordance with the approved plans (refer to condition 2.1), *Queensland Urban Drainage Manual, Capricorn Municipal Development Guidelines*, sound engineering practice and the provisions of a Development Permit for Operational Works (stormwater works).
- 8.3 All stormwater must drain to a demonstrated lawful point of discharge and must not adversely affect surrounding land or infrastructure in comparison to the pre-development conditions, including but not limited to blocking, altering or diverting existing stormwater runoff patterns or having the potential to cause damage to other infrastructure.
- 8.4 Any application for a Development Permit for Operational Works (stormwater works) must be accompanied by engineering plans with details of any new drainage systems including detention systems, inlet and outlet structures and water quality structures to implement the proposed drainage strategy.
- 8.5 The installation of gross pollutant traps must be in accordance with relevant *Australian Standards* and all maintenance of the proposed gross pollutant traps must be the responsibility of the property owner or body corporate (if applicable).
- 8.6 All proprietary stormwater quality treatment devices must be routinely checked, serviced and cleaned in accordance with the manufacturer's recommendations. Records of all maintenance activities undertaken must be kept and made available to Council upon request. Where replacement cartridges or other necessary components for the system become unavailable, an alternative system approved by Council, is required to be retrofitted into the development to achieve an equivalent pollutant reduction outcome. All maintenance cost must be borne by the site owner.
- 8.7 The proposed stormwater infrastructure internal to the site must be privately owned stormwater infrastructure and must be maintained by the owner at no cost to Council.

9.0 ROOF AND ALLOTMENT DRAINAGE WORKS

- 9.1 A Development Permit for Operational Works (roof and allotment drainage works) must be obtained prior to the commencement of any drainage works on the development site.
- 9.2 All roof and allotment drainage works must be designed and constructed in accordance with the approved plans (refer to condition 2.1), *Queensland Urban Drainage Manual, Capricorn Municipal Development Guidelines*, sound engineering practice and the provisions of a Development Permit for Operational Works (roof and allotment drainage works).
- 9.3 All roof and allotment runoff from the development must be directed to a lawful point of discharge and must not restrict, impair or change the natural flow of runoff water or cause a nuisance to surrounding land or infrastructure.

10.0 SITE WORKS

- 10.1 A Development Permit for Operational Works (site works) must be obtained prior to the commencement of any site works on the development site.
- 10.2 Any application for a Development Permit for Operational Works (site works) must be accompanied by an earthworks plan that clearly identifies the following:
- 10.2.1 the location of cut and/or fill;
 - 10.2.2 the type of fill to be used and the manner in which it is to be compacted;
 - 10.2.3 the quantum of fill to be deposited or removed and finished cut and/or fill levels;

- 10.2.4 details of any proposed access routes that are intended to be used to transport fill to or from the development site; and
 - 10.2.5 the maintenance of access roads to and from the development site so that they are free of all cut and/or fill material and cleaned as necessary.
- 10.3 All earthworks must be undertaken in accordance with *Australian Standard AS3798 "Guidelines on earthworks for commercial and residential developments"*.
- 10.4 Site works must be constructed such that they do not, at any time, in any way restrict, impair or change the natural flow of runoff water, or cause a nuisance or worsening to surrounding land or infrastructure.
- 10.5 Retaining structures above one (1) metre in height that are not incidental works to a Development Permit for Building Works, must not be constructed unless separately and specifically certified by a Registered Professional Engineer of Queensland and must be approved as part of a Development Permit for Operational Works (site works).
- 10.6 Retaining structures close to or crossing sewerage infrastructure must comply with *Queensland Development Code, Mandatory Part 1.4 "Building over or near relevant infrastructure."* The structure must be self-supporting and no additional load must be applied to Council's sewerage infrastructure. Any permit associated with the Building Over/Adjacent to Local Government Sewerage Infrastructure Policy must be obtained prior to the issue of a Development Permit for Building Works.
- 10.7 All site works must be undertaken to ensure that there is:
- 10.7.1 no increase in upstream or downstream flood levels for all levels of immunity up to a one per cent (1%) Annual exceedance probability flood event;
 - 10.7.2 no increase in velocity profiles, for which no remedy exists to prevent erosion and/or scouring. In the event that modelling shows non-compliance with the above, works must be undertaken within the system to satisfy the above criteria for development; and
 - 10.7.3 a lawful point of discharge to which the approved works drain during construction phase.
- 11.0 **BUILDING WORKS**
- 11.1 A Development Permit for Building Works must be obtained prior to the commencement of any building works on the site.
- 11.2 A Development Permit for Building Works must be obtained for the removal and/or demolition of any existing structures and proposed structures on the development site.
- 11.3 The development must comply with *Queensland Development Code, Mandatory Part 1.4 "Building over or near relevant infrastructure."* Any permit associated with the Building Over/Adjacent to Local Government Sewerage Infrastructure Policy must be obtained prior to the issue of a Development Permit for Building Works.
- 11.4 Impervious paved waste storage area/s must be provided in accordance with the approved plans (refer to condition 2.1) and the *Environmental Protection Regulation 2019* and must be:
- 11.4.1 of a sufficient size to accommodate commercial type bin for recycled waste that will be serviced by a commercial contractor plus clearances around the bins for manoeuvring and cleaning;
 - 11.4.2 If required, provided with a suitable hosecock and hoses at the refuse container area, and washdown must be drained to the sewer and fitted with an approved stormwater diversion valve arrangement in accordance with the Sewerage Trade Waste provisions and the *Plumbing and Drainage Act 2018*.

As an alternative to a washdown facility, a fully contained commercial bin cleaning service is acceptable provided no wastewater is discharged from the site to the sewer.

- 11.5 All external elements, such as air conditioners, pool and spa pumps and associated equipment, must be adequately screened from public view, to Council's satisfaction.
- 11.6 Any lighting devices associated with the development, such as sensory lighting, must be positioned on the development site and shielded so as not to cause glare or other nuisance to nearby residents and motorists. Night lighting must be designed, constructed and operated in accordance with Australian Standard AS4282 "Control of the obtrusive effects of outdoor lighting".
- 11.7 All fencing for the development must be provided in accordance with the approved plans (refer to condition 2.1).
- 12.0 LANDSCAPING WORKS
- 12.1 A Development Permit for Operational Works (landscaping works) must be obtained prior to the commencement of any landscaping works required by this development approval.
- 12.2 Landscaping must be constructed and/or established prior to the commencement of the use in all areas shown on the approved plans (refer to condition 2.1).
- 12.3 A Landscaping Plan must be submitted with any application for a Development Permit for Operational Works (landscaping works). The landscaping plans must be designed in accordance with the requirements of *Planning Scheme Policy SC6.12 - Landscape Design and Street Trees Planning Scheme Policy*.
- 12.4 At least fifty (50) per cent of all new plantings within the landscaping areas (refer to condition 2.1) must be locally native species with low water dependency.
- 12.5 Plant species must not include undesirable species identified in *Planning Scheme Policy SC6.12 - Landscape Design and Street Trees Planning Scheme Policy*.
- 12.6 The landscaped areas must be subject to:
- 12.6.1 a watering and maintenance plan during the establishment moment; and
 - 12.6.2 an ongoing maintenance and replanting programme.
- 13.0 ELECTRICITY
- 13.1 Electricity services must be provided to the development in accordance with the standards and requirements of the relevant service provider.
- 14.0 TELECOMMUNICATIONS
- 14.1 Telecommunications services must be provided to the development in accordance with the standards and requirements of the relevant service provider.
- 15.0 ASSET MANAGEMENT
- 15.1 Any alteration necessary to electricity, telephone, water mains, sewerage mains, and/or public utility installations resulting from the development or in connection with the development, must be undertaken and completed at no cost to Council.
- 15.2 Any damage to existing stormwater, water supply and sewerage infrastructure, kerb and channel, pathway or roadway (including removal of concrete slurry from public land and Council infrastructure), that occurs while any works are being carried out in association with this development approval must be repaired at full cost to the developer. This includes the reinstatement of any existing traffic signs or pavement markings that may have been removed or damaged.
- 15.3 'As Constructed' information pertaining to assets to be handed over to Council and those which may have an impact on Council's existing and future assets must be provided prior to the commencement of the use. This information must be provided in accordance with the *Asset Design and As Constructed Manual (ADAC)*.

16.0 OPERATING PROCEDURES

- 16.1 All construction materials, waste, waste skips, machinery and contractors' vehicles must be located and stored or parked within the development site. Storage of materials or parking of construction machinery or contractors' vehicles must not occur within Pennycuik Street.

ADVISORY NOTES

NOTE 1. Aboriginal Cultural Heritage

It is advised that under section 23 of the *Aboriginal Cultural Heritage Act 2003*, a person who carries out an activity must take all reasonable and practicable measures to ensure the activity does not harm Aboriginal cultural heritage (the "cultural heritage duty of care"). Maximum penalties for breaching the duty of care are listed in the Aboriginal cultural heritage legislation. The information on Aboriginal cultural heritage is available on the Department of Aboriginal and Torres Strait Islander and Partnerships website www.datsip.qld.gov.au.

NOTE 2. Asbestos Removal

Any demolition and/or removal works involving asbestos materials must be undertaken in accordance with the requirements of the *Work Health and Safety Act 2011* and *Public Health Act 2005*.

NOTE 3. General Environmental Duty

General environmental duty under the *Environmental Protection Act 1994* prohibits unlawful environmental nuisance caused by noise, aerosols, particles, dust, ash, fumes, light, odour or smoke beyond the boundaries of the development site during all stages of the development including earthworks, construction and operation.

NOTE 4. General Safety Of Public During Construction

The *Work Health and Safety Act 2011* and *Manual of Uniform Traffic Control Devices* must be complied with in carrying out any construction works, and to ensure safe traffic control and safe public access in respect of works being constructed on a road.

NOTE 5. Infrastructure Charges Notice

This application is subject to infrastructure charges in accordance with Council policies. The charges are presented on an Infrastructure Charges Notice.

The following is an extract from the *Planning Act 2016* (Chapter 6)

Appeal rights

229 Appeals to tribunal or P&E Court

- (1) Schedule 1 states—
 - (a) matters that may be appealed to—
 - (i) either a tribunal or the P&E Court; or
 - (ii) only a tribunal; or
 - (iii) only the P&E Court; and
 - (b) the person—
 - (i) who may appeal a matter (the **appellant**); and
 - (ii) who is a respondent in an appeal of the matter; and
 - (iii) who is a co-respondent in an appeal of the matter; and
 - (iv) who may elect to be a co-respondent in an appeal of the matter.
 - (2) An appellant may start an appeal within the appeal period.
 - (3) The **appeal period** is—
 - (a) for an appeal by a building advisory agency—10 business days after a decision notice for the decision is given to the agency or
 - (b) for an appeal against a deemed refusal—at any time after the deemed refusal happens; or
 - (c) for an appeal against a decision of the Minister, under chapter 7, part 4, to register premises or to renew the registration of premises—20 business days after a notice is published under section 269(3)(a) or (4); or
 - (d) for an appeal against an infrastructure charges notice—20 business days after the infrastructure charges notice is given to the person; or
 - (e) for an appeal about a deemed approval of a development application for which a decision notice has not been given—30 business days after the applicant gives the deemed approval notice to the assessment manager; or
 - (f) for any other appeal—20 business days after a notice of the decision for the matter, including an enforcement notice, is given to the person.
- Note—
See the P&E Court Act for the court's power to extend the appeal period.

230 Notice of appeal

- (1) An appellant starts an appeal by lodging, with the registrar of the tribunal or P&E Court, a notice of appeal that—
 - (a) is in the approved form; and
 - (b) succinctly states the grounds of the appeal.
- (2) The notice of appeal must be accompanied by the required fee.
- (3) The appellant or, for an appeal to a tribunal, the registrar must, within the service period, give a copy of the notice of appeal to—

- (a) the respondent for the appeal; and
 - (b) each co-respondent for the appeal; and
 - (c) for an appeal about a development application under schedule 1, table 1, item 1—each principal submitter for the development application; and
 - (d) for an appeal about a change application under schedule 1, table 1, item 2—each principal submitter for the change application; and
 - (e) each person who may elect to become a co-respondent for the appeal, other than an eligible submitter who is not a principal submitter in an appeal under paragraph (c) or (d); and
 - (f) for an appeal to the P&E Court—the chief executive; and
 - (g) for an appeal to a tribunal under another Act—any other person who the registrar considers appropriate.
- (4) The **service period** is—
 - (a) if a submitter or advice agency started the appeal in the P&E Court—2 business days after the appeal is started; or
 - (b) otherwise—10 business days after the appeal is started.
 - (5) A notice of appeal given to a person who may elect to be a co-respondent must state the effect of subsection
 - (6) A person elects to be a co-respondent by filing a notice of election, in the approved form, within 10 business days after the notice of appeal is given to the person.

231 Other appeals

- (1) Subject to this chapter, schedule 1 and the P&E Court Act, unless the Supreme Court decides a decision or other matter under this Act is affected by jurisdictional error, the decision or matter is non-appealable.
- (2) The Judicial Review Act 1991, part 5 applies to the decision or matter to the extent it is affected by jurisdictional error.
- (3) A person who, but for subsection (1) could have made an application under the Judicial Review Act 1991 in relation to the decision or matter, may apply under part 4 of that Act for a statement of reasons in relation to the decision or matter.
- (4) In this section— **decision** includes—
 - (a) conduct engaged in for the purpose of making a decision; and
 - (b) other conduct that relates to the making of a decision; and
 - (c) the making of a decision or the failure to make a decision; and
 - (d) a purported decision; and
 - (e) a deemed refusal.

non-appealable, for a decision or matter, means the decision or matter—

- (a) is final and conclusive; and
- (b) may not be challenged, appealed against, reviewed, quashed, set aside or called into question in any other way under the Judicial Review Act 1991 or otherwise, whether by the Supreme Court, another court, a tribunal or another entity; and
- (c) is not subject to any declaratory, injunctive or other order of the Supreme Court, another court, a tribunal or another entity on any ground.

232 Rules of the P&E Court

- (1) A person who is appealing to the P&E Court must comply with the rules of the court that apply to the appeal.
- (2) However, the P&E Court may hear and decide an appeal even if the person has not complied with rules of the P&E Court.

Schedule 1

Appeals section 229

1 Appeal rights and parties to appeals

- (1) Table 1 states the matters that may be appealed to—(a) the P&E court; or (b) a tribunal.
- (2) However, table 1 applies to a tribunal only if the matter involves—
- (a) the refusal, or deemed refusal of a development application, for—
 - (i) a material change of use for a classified building; or
 - (ii) operational work associated with building work, a retaining wall, or a tennis court; or
 - (b) a provision of a development approval for—
 - (i) a material change of use for a classified building; or
 - (ii) operational work associated with building work, a retaining wall, or a tennis court; or
 - (c) if a development permit was applied for—the decision to give a preliminary approval for—
 - (i) a material change of use for a classified building; or
 - (ii) operational work associated with building work, a retaining wall, or a tennis court; or
 - (d) a development condition if—
 - (i) the development approval is only for a material change of use that involves the use of a building classified under the Building Code as a class 2 building; and
 - (ii) the building is, or is proposed to be, not more than 3 storeys; and
 - (iii) the proposed development is for not more than 60 sole-occupancy units; or
 - (e) a decision for, or a deemed refusal of, an extension application for a development approval that is only for a material change of use of a classified building; or
 - (f) a decision for, or a deemed refusal of, a change application for a development approval that is only for a material change of use of a classified building; or
 - (g) a matter under this Act, to the extent the matter relates to—
 - (i) the Building Act, other than a matter under that Act that may or must be decided by the Queensland Building and Construction Commission; or
 - (ii) the Plumbing and Drainage Act, part 4 or 5; or
 - (h) a decision to give an enforcement notice in relation to a matter under paragraphs (a) to (g); or
 - (i) a decision to give an infrastructure charges notice; or
 - (j) the refusal, or deemed refusal, of a conversion application; or
 - (k) a matter that, under another Act, may be appealed to the tribunal; or
 - (l) a matter prescribed by regulation.
- (3) Also, table 1 does not apply to a tribunal if the matter involves—
- (a) for a matter in subsection (2)(a) to (d)—
 - (i) a development approval for which the development application required impact assessment; and
 - (ii) a development approval in relation to which the assessment manager received a properly made submission for the development application; or
 - (b) a provision of a development approval about the identification or inclusion, under a variation approval, of a matter for the development.
- (4) Table 2 states the matters that may be appealed only to the P&E Court.
- (5) Table 3 states the matters that may be appealed only to the tribunal.
- (6) In each table—
- (a) column 1 states the appellant in the appeal; and
 - (b) column 2 states the respondent in the appeal; and
 - (c) column 3 states the co-respondent (if any) in the appeal; and
 - (d) column 4 states the co-respondents by election (if any) in the appeal.
- (7) If the chief executive receives a notice of appeal under section 230(3)(f), the chief executive may elect to be a co-respondent in the appeal.

Table 1
Appeals to the P&E Court and, for certain matters, to a tribunal

<p>1. Development applications An appeal may be made against—</p> <ul style="list-style-type: none"> (a) the refusal of all or part of the development application; or (b) the deemed refusal of the development application; or (c) a provision of the development approval; or (d) if a development permit was applied for—the decision to give a preliminary approval. 			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
The applicant	The assessment manager	If the appeal is about a concurrence	1 A concurrence agency that is not a co-respondent

Table 1
Appeals to the P&E Court and, for certain matters, to a tribunal

		agency's referral response—the concurrence agency	2 If a chosen Assessment manager is the respondent—the prescribed assessment manager 3 Any eligible advice agency for the application 4 Any eligible submitter for the application
<p>2. Change applications An appeal may be made against—</p> <p>(a) a responsible entity's decision for a change application, other than a decision made by the P&E court; or</p> <p>(b) a deemed refusal of a change application.</p>			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
1 The applicant 2 If the responsible entity is the assessment manager—an affected entity that gave a pre-request notice or response notice	The responsible entity	If an affected entity starts the appeal—the applicant	1 A concurrence agency for the development application 2 If a chosen assessment manager is the respondent—the prescribed assessment manager 3 A private certifier for the development application 4 Any eligible advice agency for the change application 5 Any eligible submitter for the change application
<p>3. Extension applications An appeal may be made against—</p> <p>(a) the assessment manager's decision about an extension application; or</p> <p>(b) a deemed refusal of an extension application.</p>			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
1 1 The applicant 2 For a matter other than a deemed refusal of an extension application – a concurrence agency, other than the chief executive, for the application	The assessment manager	If a concurrence agency starts the appeal – the applicant	If a chosen assessment manager is the respondent – the prescribed assessment manager
<p>4. Infrastructure charges notices An appeal may be made against an infrastructure charges notice on 1 or more of the following grounds</p> <p>a) The notice involved an error relating to –</p> <p>(i) The application of the relevant adopted charge; or</p> <p>Examples of errors in applying an adopted charge –</p> <ul style="list-style-type: none"> • The incorrect application of gross floor area for a non-residential development • Applying an incorrect 'use category', under a regulation, to the development <p>(i) The working out of extra demands, for section 120; or</p> <p>(ii) An offset or refund; or</p> <p>b) The was no decision about an offset or refund; or</p> <p>c) If the infrastructure charges notice states a refund will be given – the timing for giving the refund; or</p> <p>d) The amount of the charge is so unreasonable that no reasonable relevant local government could have</p>			

Table 1 Appeals to the P&E Court and, for certain matters, to a tribunal			
imposed the amount.			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
The person given the infrastructure charges notice	The local government that gave the infrastructure charges notice	-	-
5. Conversion applications An appeal may be made against— (a) the refusal of a conversion application; or (b) a deemed refusal of a conversion application.			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
The applicant	The local government to which the conversion application was made	-	-
6. Enforcement notices An appeal may be made against the decision to give an enforcement notice.			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
The person given the enforcement notice	The enforcement authority	-	If the enforcement authority is not the local government for the premises in relation to which the offence is alleged to have happened—the local government

Table 2 Appeals to the P&E Court only			
1. Appeals from tribunal An appeal may be made against a decision of a tribunal, other than a decision under section 252, on the ground of— (a) an error or mistake in law on the part of the tribunal; or (b) jurisdictional error.			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
A party to the proceedings for the decision	The other party to the proceedings for the decision	-	-
2. Eligible submitter appeals An appeal may be made against the decision to give a development approval, or an approval for a change application, to the extent that the decision relates to— (a) any part of the development application for the development approval that required impact assessment; or (b) a variation request.			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent	Column 4 Co-respondent by election

Table 2 Appeals to the P&E Court only			
		(if any)	(if any)
1 For a development application—an eligible submitter for the development application 2 For a change application—an eligible submitter for the change application	1 For a development application—the assessment manager 2 For a change application—the responsible entity	1 The applicant 2 If the appeal is about a concurrence agency's referral response—the concurrence agency	Another eligible submitter for the application
<p>3. Eligible submitter and eligible advice agency appeals</p> <p>An appeal may be made against a provision of a development approval, or failure to include a provision in the development approval, to the extent the matter relates to—</p> <p>(a) any part of the development application or the change application, for the development approval, that required impact assessment; or</p> <p>(b) a variation request.</p>			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
1 For a development application—an eligible submitter for the development application 2 For a change application—an eligible submitter for the change application 3 An eligible advice agency for the development application or change application	1 For a development application—the assessment manager 2 For a change application—the responsible entity	1 The applicant 2 If the appeal is about a concurrence agency's referral response—the concurrence agency	Another eligible submitter for the application
<p>4. Compensation claims</p> <p>An appeal may be made against—</p> <p>(a) a decision under section 32 about a compensation claim; or</p> <p>(b) a decision under section 265 about a claim for compensation; or</p> <p>(c) a deemed refusal of a claim under paragraph (a) or (b).</p>			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
A person dissatisfied with the decision	The local government to which the claim was made	-	-
<p>5. Registered premises</p> <p>An appeal may be made against a decision of the Minister under chapter 7, part 4.</p>			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
1 A person given a decision notice about the decision 2 If the decision is to register premises or	The Minister	-	If an owner or occupier starts the appeal – the owner of the registered premises

Table 2 Appeals to the P&E Court only			
renew the registration of premises—an owner or occupier of premises in the affected area for the registered premises who is dissatisfied with the decision			
<p>6. Local laws An appeal may be made against a decision of a local government, or conditions applied, under a local law about—</p> <p>(a) the use of premises, other than a use that is the natural and ordinary consequence of prohibited development; or</p> <p>(b) the erection of a building or other structure.</p>			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
A person who— (a) applied for the decision; and (b) is dissatisfied with the decision or conditions.	The local government	-	-

Table 3 Appeals to the tribunal only			
<p>1. Building advisory agency appeals An appeal may be made against giving a development approval for building work to the extent the building work required code assessment against the building assessment provisions.</p>			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
A building advisory agency for the development application related to the approval	The assessment manager	The applicant	1 A concurrence agency for the development application related to the approval 2 A private certifier for the development application related to the approval
<p>3. Certain decisions under the Building Act and the Plumbing and Drainage Act An appeal may be made against a decision under—</p> <p>(a) the Building Act, other than a decision made by the Queensland Building and Construction Commission; or</p> <p>(b) the Plumbing and Drainage Act, part 4 or 5.</p>			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent (if any)	Column 4 Co-respondent by election (if any)
A person who received, or was entitled to receive, notice of the decision	The person who made the decision	-	-
<p>4. Local government failure to decide application under the Building Act An appeal may be made against a local government's failure to decide an application under the Building Act within the period required under that Act.</p>			
Column 1 Appellant	Column 2 Respondent	Column 3 Co-respondent	Column 4 Co-respondent by election

Table 3			
Appeals to the tribunal only			
		(if any)	(if any)
A person who was entitled to receive, notice of the decision	The local government to which the application was made	-	-